



CORRIGENDUM

SUBJECT: CORRIGENDUM NO. 1

Date: 03/08/2019

TENDER NO.: RGPPL/C&M/CS-2761/OT-94 dated : 16.07.2019

NAME OF WORK: Design, Supply, Erection & Commissioning of Electro-chlorination System for Circulating Water System of RGPPL.

This is in reference to aforesaid Tender, following changes/additions/clarifications are incorporated in tender documents:

Sr. No.	As per tender document	Revised
clause no. 10.2 (Pg#33)	1.1 Liquidated damages for reduction in capacity: a. If the total train capacity of Electro-Chlorination System (including three streams) is less than 750 Kg/hr of chlorine production, or b. If the total train capacity of Electro-Chlorination System (individual streams) is less than 250 Kg/hr of chlorine production, there shall be pro-rata deduction from the cost towards the design and supply considering total capacity as minimum 750 Kg/hr or individual capacity of 250 Kg/Hr.	1.1 Liquidated damages for reduction in capacity: a. If the total train capacity of Electro-Chlorination System (including three streams) is less than 750 <u>Kg/day</u> of chlorine production, or b. If the total train capacity of Electro-Chlorination System (individual streams) is less than <u>250 Kg/day</u> of chlorine production, there shall be pro-rata deduction from the cost towards the design and supply considering total capacity as minimum 750 <u>Kg/day</u> or individual capacity of 250 <u>Kg/day</u> .
clause 3.0 (pg#25)	Though, normally, 2 working and 1 standby is anticipated, the system offered should be so designed to be hydraulically stable and capable of running all the electro-chlorinators in parallel and store the resultant hypo generated, if necessitates	Though, normally, 2 working and 1 standby is anticipated, the system offered should be so designed to be hydraulically stable and capable of running all the <u>three</u> electro-chlorinators in parallel and store the resultant hypo generated, if necessitates

All other Terms & Conditions of the tender documents will remain unchanged.

This Corrigendum No.1 shall form an integral part of this tender. A copy of the same is to be submitted along with the bid.

For & behalf of RGPPL

